

**TRANSFORMER CONTROLLED
40°C AMBIENT TEMPERATURE
(BASE CONTINUOUS RATING)**

**INDUSTRIAL
50 Hz
4 Pole**

	3 PHASE (6 WIRE)				1 PHASE (6 WIRE)			
POWER FACTOR	0.8		0.85		0.8		0.85	
VOLTS :	380 - 415		380 - 415		220 - 240		220 - 240	
	kVA	kW	kVA	kW	kVA	kW	kVA	kW

BCI 164A	6.3	5.0	7.5	6.4	4.0	3.2	4.8	4.1
BCI 164B	8.5	6.8	10.0	8.5	5.6	4.5	6.6	5.6
BCI 164C	10.5	8.4	12.5	10.6	7.0	5.6	8.2	7.0
BCI 164D	12.5	10.0	15.1	12.8	8.1	6.5	9.8	8.3

BCI 184E	17.5	14.0	20.0	17.0	11.5	9.2	13.1	11.1
BCI 184F	20.0	16.0	25.1	21.3	13.5	10.8	16.5	14.0
BCI 184G	25.0	20.0	30.0	25.5	16.8	13.4	20.0	17.0

BCAI 164A	6.3	5.0	7.5	6.4	4.0	3.2	4.8	4.1
BCAI 164B	8.5	6.8	10.0	8.5	5.6	4.5	6.6	5.6
BCAI 164C	10.5	8.4	12.5	10.6	7.0	5.6	8.2	7.0
BCAI 164D	12.5	10.0	15.1	12.8	8.1	6.5	9.8	8.3
BCAI 164E	16.6	13.3	19.0	16.2	10.9	8.7	12.4	10.5
BCAI 164F	19.0	15.2	23.8	20.2	12.8	10.2	15.6	13.3
BCAI 164G	23.8	19.0	28.5	24.2	15.9	12.7	19.0	16.2

BCLI 164A	6.3	5.0	7.5	6.4	4.0	3.2	4.8	4.1
BCLI 164B	8.5	6.8	10.0	8.5	5.6	4.5	6.6	5.6
BCLI 164C	10.5	8.4	12.5	10.6	7.0	5.6	8.2	7.0
BCLI 164D	12.5	10.0	15.1	12.8	8.1	6.5	9.8	8.3
BCLI 184E	17.5	14.0	20.0	17.0	11.5	9.2	13.1	11.1
BCLI 184F	20.0	16.0	25.1	21.3	13.5	10.8	16.5	14.0

UCI 224C	30.0	24.0	35.0	29.8	20.0	16.0	23.5	20.0
UCI 224D	35.0	28.0	42.5	36.1	23.5	18.8	28.5	24.2
UCI 224E	42.5	34.0	50.0	42.5	28.5	22.8	33.5	28.5
UCI 224F	55.0	44.0	65.0	55.3	36.5	29.2	43.0	36.6
UCI 224G	65.0	52.0	75.0	63.8	43.5	34.8	50.0	42.5

UCDI 224C	30.0	24.0	35.0	29.8	20.0	16.0	23.5	20.0
UCDI 224D	35.0	28.0	42.5	36.1	23.5	18.8	28.5	24.2
UCDI 224E	42.5	34.0	50.0	42.5	28.5	22.8	33.5	28.5
UCDI 224F	55.0	44.0	65.0	55.3	36.5	29.2	43.0	36.6
UCDI 224G	65.0	52.0	75.0	63.8	43.5	34.8	50.0	42.5

Winding number is specific to output voltage.
These generators will only operate at the voltage specified at time of order.