

**TRANSFORMER CONTROLLED
40°C AMBIENT TEMPERATURE
(BASE CONTINUOUS RATING)**

**INDUSTRIAL
60 Hz
4 Pole**

	3 PHASE (6 WIRE)				1 PHASE (6 WIRE)			
POWER FACTOR	0.8		0.85		0.8		0.85	
VOLTS :	480		480		220 - 240		220 - 240	
	kVA	kW	kVA	kW	kVA	kW	kVA	kW

BCI 164A	7.8	6.2	9.1	7.7	5.0	4.0	5.8	4.9
BCI 164B	10.6	8.5	12.0	10.2	7.0	5.6	8.0	6.8
BCI 164C	13.1	10.5	15.1	12.8	8.8	7.0	10.0	8.5
BCI 164D	15.6	12.5	17.5	14.9	10.0	8.0	11.2	9.5

BCI 184E	21.9	17.5	24.0	20.4	14.4	11.5	15.8	13.4
BCI 184F	25.0	20.0	30.0	25.5	16.9	13.5	20.0	17.0
BCI 184G	31.3	25.0	35.1	29.8	21.0	16.8	23.5	20.0

BCAI 164A	7.8	6.2	9.0	7.7	5.0	4.0	5.7	4.8
BCAI 164B	10.6	8.5	12.0	10.2	7.0	5.6	8.0	6.8
BCAI 164C	13.1	10.5	15.0	12.8	8.8	7.0	10.0	8.5
BCAI 164D	15.6	12.5	17.5	14.9	10.0	8.0	11.2	9.5
BCAI 164E	20.8	16.6	22.8	19.4	13.6	10.9	15.0	12.8
BCAI 164F	23.8	19.0	28.5	24.2	16.0	12.8	19.0	16.2
BCAI 164G	28.5	22.8	33.3	28.3	19.9	15.9	22.3	19.0

BCLI 164A	7.8	6.2	9.0	7.7	5.0	4.0	5.7	4.8
BCLI 164B	10.6	8.5	12.0	10.2	7.0	5.6	8.0	6.8
BCLI 164C	13.1	10.5	15.0	12.8	8.8	7.0	10.0	8.5
BCLI 164D	15.6	12.5	17.5	14.9	10.0	8.0	11.2	9.5
BCLI 184E	21.9	17.5	24.0	20.4	14.4	11.5	15.8	13.4
BCLI 184F	25.0	20.0	30.0	25.5	16.9	13.5	20.0	17.0

UCI 224C	37.5	30.0	42.5	36.1	25.0	20.0	28.0	23.8
UCI 224D	44.0	35.2	49.0	41.7	29.4	23.5	32.5	27.6
UCI 224E	53.0	42.4	60.0	51.0	35.6	28.5	40.0	34.0
UCI 224F	69.0	55.2	75.0	63.8	45.6	36.5	50.0	42.5
UCI 224G	81.0	64.8	88.0	74.8	54.4	43.5	59.0	50.2

UCDI 224C	37.5	30.0	42.5	36.1	25.0	20.0	28.0	23.8
UCDI 224D	44.0	35.2	49.0	41.7	29.4	23.5	32.5	27.6
UCDI 224E	53.0	42.4	60.0	51.0	35.6	28.5	40.0	34.0
UCDI 224F	69.0	55.2	75.0	63.8	45.6	36.5	50.0	42.5
UCDI 224G	81.0	64.8	88.0	74.8	54.4	43.5	59.0	50.2

Winding number is specific to output voltage.
These generators will only operate at the voltage specified at time of order.