

DRG. SIZE C	REL. PHASE P	PART No 19-1092	ISSUE A
----------------	-----------------	--------------------	------------


IF IN DOUBT-ASK
DO NOT SCALE

DIMENSIONS						
FRAME	"A"	"B"	"C"	"D"	"X"	NETT WT. (Kg)
PI4EI	566	484	185	227	213	136
PI4FI	581	499	200	241	227	144.5
PI4GI	621	539	240	261	247	161

COUPLING DISC					
SAE	"AN"	"AM"	"AP"	"AR"	"V"
6.5	30.2	6	8.7	200.0	215.8
7.5	30.2	8	8.7	222.2	241.2
8	62	6	11	244.5	263.4
10	53.8	8	11	295.3	314.2

135 MIN. CLEARANCE REQUIRED
WHEN FITTED WITH EBS

50 MIN. AIR ENTRY WHEN
NOT FITTED WITH EBS



- ① -REMOVABLE COVER FOR ACCESS TO ELECTRONIC CONTROL
- ② -REMOVABLE COVER FOR ACCESS TO MAIN TERMINALS

CONFIDENTIAL PROPERTY OF
CUMMINS GENERATOR TECHNOLOGIES LTD.

PI E/F/G LARGE TERM. BOX
I- BEARING ALTERNATOR
SAE 4 ADAPTOR
SAE 6.5, 7.5, 8 & 10 COUPLING
REMOVABLE SIDE PANELS

DIMENSIONS IN MILLIMETRES (MM) AT 20°C			PROJECTION 		
DRAWN	DW	15/10/07	DRG. SIZE	SCALE 3:10	
CHECKED	DW	15/10/07	REL. PHASE	PART No 19-1092	
APPROVED	DPC	15/10/07	PRO/ENGINEER	ISSUE A	
UNLIMITED DIMS ± --			SHEET 1 OF 1 SHEETS		

4-9111-66	A	DW	15/10/07	ORIGINAL ISSUE
MOD.	ISSUE	DRAWN	DATE	MODIFICATION