DRG.SIZE	REL. PHASE	PART No	ISSUE
C	P	19-1118	A

IF IN DOUBT-ASK
DO NOT SCALE

135 MIN. CLEARANCE REQUIRED WHEN FITTED WITH EBS.

50 MIN, AIR ENTRY WHEN NOT FITTED WITH EBS.

SHAFT EXTENSION DETAIL



DIMENSIONS						
FRAME	"A"	"B"	"C"	"D"	"X"	NETT WT.(Kg)
P14H2	689	359	371	780	330	184
P14J2	728	389	386	810	345	195
P14K2	743	404	392	825	350	204

ADAPTOR DIMENSIONS							
SAE	"M"	"N"	"P"	"U"	"V"	"W"	"Y"
2	12	11	466.7	15°	432	447.6	495
3	12	11	428.6	15°	396	409.5	451
4	12	11	381.0	15°	352	361.9	403
5	8	11	333.3	22.5°	301	314.3	356



(1)-REMOVABLE COVER FOR ACCESS TO ELECTRONIC CONTROL

(2)-REMOVABLE COVER FOR ACCESS TO MAIN TERMINALS

APPROVED DOCUMENT

MOD.	ISSUE	DRAWN	DATE	MODIFICATION
-	-	-	-	-
4-9111-81	A	DW	7/11/07	ORIGINAL ISSUE

CONFIDENTIAL PROPERTY OF CUMMINS GENERATOR TECHNOLOGIES LTD.

DIMENSIONS IN MILLIMETRES (MM) AT 20°C

UNLIMITED DIMS ± --

PROJECTION

DRAWN	DW	7/11/07
CHECKED	DW	7/11/07
APPROVED	DPC	7/11/07

PI H/J/K 4-POLE 2-BEARING ALTERNATOR WITH COUPLING ADAPTOR LARGE TERMINAL BOX REMOVABLE SIDE PANELS

DRG. SIZE	SCALE	3:10
C	PART No 19-1118	ISSUE A
REL. PHASE P	SHEET 1 OF 1	SHEETS
Pro/ENGINEER		